

Approved Body authorised by the MCA

UNITED KINGDOM CERTIFICATE OF CONFORMITY

Issued in accordance with

The Merchant Shipping (Marine Equipment) Regulations

2016 SI 2016/1025, as amended

Certificate No. 164.106/1121/WCL MER0528QA

This is to certify that in compliance with The Merchant Shipping (Marine Equipment) Regulations 2016 SI 2016/1025 as amended by the Merchant Shipping (Marine Equipment) (Amendment etc.) (EU Exit) Regulations 2019 SI 2019/470 and relevant UK carriage requirement instruments, the product detailed below has been tested in accordance with the appropriate international instruments contained therein.

This certificate is issued to:

**F Ball and Co. Ltd.
Station Road, Cheddleton, Leek,
Staffordshire, ST13 7RS, UK**

To certify also that a Surveyor representing Warringtonfire Testing and Certification Limited did at their request attend at the works of F Ball and Co Ltd. on the 8th January 2014 and annually thereafter for the purpose of examining the production and factory production control systems for this product.

Product Description - Heavy duty flooring smoothing underlayment
Product Type - Primary deck covering (Item Number UK/3.1)
Reference - "Stopgap 300 HD"
Modules used - (D)

The particulars of which are given on this certificate, to verify compliance with the requirements of the International Convention for the Safety of Life at Sea (SOLAS) 1974 Regulation II-2/4, II-2/6 and X/3.

The manufacturer is allowed to affix the U.S. Coast Guard approval number 164.106/1121/WCL MER0528 as allowed by the Merchant Shipping (Marine Equipment) (Amendment) (UK and US Mutual Recognition Agreement) (EU Exit) Regulations 2019 SI 2019/1304 ('the Regulations') dated October 7th, 2019.



P. Duggan, Certification Manager
Warringtonfire Testing and Certification Limited
Holmesfield Road
Warrington WA1 2DS

Date of issue: 01/01/2021
Date of expiry: 20/02/2024

UK Approved Body No. 1121



1121/2021

Example for the Application of the "Mark of Conformity" where:

1121 is the number of the Approved Body responsible for quality surveillance module.

2021 is the year in which the mark is affixed.

Description of Product as Prototype Tested:

The product is constructed as described in the test reports referenced in the following certificate.

| UK Type-Examination Certificate No. | Approved Body | Date of Issue |
|--|--|----------------------|
| 164.106/1121/WCL MER0528TE | Warringtonfire Testing and Certification Limited | 01/01/2021 |

| Regulation No | Testing Standard | Result | Report and Date |
|--|---|---------------|--|
| II-2/4, II-2/6, X/3 and IMO MSC/Circ.1120, | IMO Resolution MSC 307(88), Annex 1: Part 5 | Pass | WF 407971 and WF 407972, formal and indicative Surface Flammability tests to IMO Resolution MSC 307(88) Annex 1: Part 5. Tested January 2019. |
| | IMO Resolution MSC 307(88), Annex 1: Part 2 | Pass | Smoke and Toxicity is satisfied by meeting the total heat release (Q_t) and peak heat release (Q_p) as stated in IMO Fire Test Procedures Code, Annex 2 Section 2.2. |

Marking & Identification affixed to the product:

| | |
|-----------------------------|--|
| Manufacturer Name | F Ball and Co. Ltd. |
| Manufacturer Address | Station Road, Cheddleton, Leek, Staffordshire, ST13 7RS, UK |
| Product Reference | "Stopgap 300 HD" |
| Approved Authority | Warringtonfire Testing and Certification Limited |

Warringtonfire Testing and Certification Limited
Holmesfield Road
Warrington WA1 2DS

UK Approved Body No. 1121