

Approved Body authorised by the MCA

UNITED KINGDOM CERTIFICATE OF CONFORMITY

Issued in accordance with

The Merchant Shipping (Marine Equipment) Regulations

2016 SI 2016/1025, as amended

Certificate No. 164.106/1121/WCL MER0389QA

This is to certify that in compliance with The Merchant Shipping (Marine Equipment) Regulations 2016 SI 2016/1025 as amended by the Merchant Shipping (Marine Equipment) (Amendment etc.) (EU Exit) Regulations 2019 SI 2019/470 and relevant UK carriage requirement instruments, the product detailed below has been tested in accordance with the appropriate international instruments contained therein.

This certificate is issued to:

**F Ball and Co. Ltd.
Station Road, Cheddleton, Leek,
Staffordshire, ST13 7RS, UK**

To certify also that a Surveyor representing Warringtonfire Testing and Certification Limited did at their request attend at the works of F Ball and Co Ltd. on the 8th January 2014 and annually thereafter for the purpose of examining the production and factory production control systems for this product.

Product Description - **Primary Deck Covering**
Product Type - **Item Number UK/3.1 - Primary Deck Covering**
Reference - **"Stopgap 700 Superflex"**
Modules used - **(D)**

The particulars of which are given on this certificate, to verify compliance with the requirements of the International Convention for the Safety of Life at Sea (SOLAS) 1974 Regulation II-2/4, II-2/6 and X/3.

The manufacturer is allowed to affix the U.S. Coast Guard approval number 164.106/1121/WCL MER0389 as allowed by the Merchant Shipping (Marine Equipment) (Amendment) (UK and US Mutual Recognition Agreement) (EU Exit) Regulations 2019 SI 2019/1304 ('the Regulations') dated October 7th, 2019.



P. Duggan, Certification Manager
Warringtonfire Testing and Certification Limited
Holmesfield Road
Warrington WA1 2DS

Date of issue: 01/01/2021
Date of expiry: 05/01/2025

UK Approved Body No. 1121



1121/2021

Example for the Application of the "Mark of Conformity" where:
1121 is the number of the Approved Body responsible for quality surveillance module.
2021 is the year in which the mark is affixed.

Description of Product as Prototype Tested:

The product is constructed as described in the test reports referenced in the following certificate.

UK Type-Examination Certificate No.	Approved Body	Date of Issue
--	----------------------	----------------------

164.106/1121/WCL MER0389TE	Warringtonfire Testing and Certification Limited	01/01/2021
----------------------------	--	------------

Regulation No	Testing Standard	Result	Date
----------------------	-------------------------	---------------	-------------

II-2/4 II-2/6 X/3 MSC Circ 1120	IMO FTPC Part 6 and Annex 2	Pass	WF 184459 Dated July 2009 Smoke and Toxicity is satisfied by meeting the total heat release (Q_t) and peak heat release (Q_p) as stated in IMO Fire Test Procedures Code, Annex 2 Section 2.2.
---	--------------------------------	------	---

Marking & Identification affixed to the product:

Manufacturer Name	F Ball and Co. Ltd.
Manufacturer Address	Station Road, Cheddleton, Leek, Staffordshire, ST13 7RS, UK
Product Reference	"Stopgap 700 Superflex"
Approved Authority	Warringtonfire Testing and Certification Limited

Warringtonfire Testing and Certification Limited
Holmesfield Road
Warrington WA1 2DS

Warringtonfire Testing and Certification Limited
UK Approved Body No. 1121