

# Attestation

## BREEAM®

On the 27<sup>th</sup> of August Eurofins Product Testing A/S received a sample of an adhesive with the product name:

### Styccobond F73 Plus

supplied by

### F. Ball and Co. Ltd.

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 testing standards (See test report no.392-2025-00429301\_A\_EN).

Deviations from the referenced test methods were registered. (See section 4.4 in test report no. 392-2025-00429301\_A\_EN).

**The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:**

- **BREEAM® International: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM International: New Construction 2025, Technical Manual – SD6073: Hea 04 Indoor Air Quality (version 7.0.0 of July 2025).
- **BREEAM® UK: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM UK: New Construction 2025, Technical Manual – SD6074: Hea 04 Indoor Air Quality (version 7.0.0 of July 2025).
- **BREEAM® NL: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM-NL: Nieuwbouw en renovatie utiliteitsbouw 2025, Technical Manual: Hea 04 Gezonde binnenlucht (version 6.1.1 of February 2025).
- **BREEAM® SE: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM SE: New Construction 2023, Technical Manual: Hea 02 Indoor Air Quality (version 6.0. of January 2023).
- **BREEAM® NOR: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM NOR: New Construction 2024, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.1.1 of December 2024).

8 October 2025



Tobias Sandbaek  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager