

Confirmation

BREEAM®

On 9 September 2020, Eurofins Product Testing A/S received a sample of a flooring adhesive with the product name:

Styccobond F49 Hybrid PS

supplied by

F. Ball and Co. Ltd.

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 testing standards (See test report no. 392-2020-00389701_G_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:

- **BREEAM® International: Compliance with Exemplary level criteria on VOC emission** of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor Air Quality (version SD233 issue 2.0 of July 2017)
- **BREEAM® UK: Compliance with Exemplary level criteria on VOC emission** of BREEAM UK: New Construction 2018, Technical Manual: Hea 02 Indoor Air Quality (version SD5078 issue 3.0 of July 2019)

22 December 2020



Janne Rothmann Norup
Analytical Service Manager